

Message

From: Martinson, Mathew [/O=EXCHANGELABS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=07993C0BB86D42E4806A6EAE5184A611-MARTINSON,]
Sent: 8/15/2019 3:43:12 PM
To: Contreras, Peter [/o=ExchangeLabs/ou=Exchange Administrative Group (FYDIBOHF23SPDLT)/cn=Recipients/cn=3c7e515833814b74a7ebafcfef8b6322-Contreras, Peter]
CC: Baron, Adam [/o=ExchangeLabs/ou=Exchange Administrative Group (FYDIBOHF23SPDLT)/cn=Recipients/cn=563ef058707d4930868c6cf1e0828a43-Baron, Adam]
Subject: RE: EPA R10 review of monitoring data related to Warm Springs BWN

This is good to hear. I talked with Craig Haugland, the Acting Director of Sanitation Facilities Construction. He personally spent some time onsite again in the past few weeks. Derek Hancey is out there today.

Mathew J. Martinson, P.E., BCEE
CAPT, USPHS
Branch Chief, Permitting, Drinking Water and Infrastructure Branch
U.S. EPA, Region 10
Phone: 206-553-6334 (Direct)

From: Contreras, Peter <Contreras.Peter@epa.gov>
Sent: Thursday, August 15, 2019 8:39 AM
To: Martinson, Mathew <martinson.mathew@epa.gov>
Subject: FW: EPA R10 review of monitoring data related to Warm Springs BWN

Hi Mat – this went out end of day yesterday.

Thanks,

Peter



Peter Contreras, Chief
Field, Data & Drinking Water Enforcement Section
Water Enforcement & Field Branch
Enforcement and Compliance Assurance Division
Seattle, WA (206) 553-6708

From: Baron, Adam <Baron.Adam@epa.gov>
Sent: Wednesday, August 14, 2019 4:10 PM
To: Travis Wells <travis.wells@wstribes.org>; Chico Holliday <chico.holliday@wstribes.org>; Alyssa Macy <alyssa.macy@wstribes.org>
Cc: Contreras, Peter <Contreras.Peter@epa.gov>; Affeldt, Chris <Affeldt.Christopher@epa.gov>; Duvil, Ricardi <duvil.ricardi@epa.gov>; Thurmon, Clarke <Thurmon.Clarke@epa.gov>; Ellen H. Grover <ehg@karnopp.com>
Subject: EPA R10 review of monitoring data related to Warm Springs BWN

Travis/ Chico/ Alyssa -

I've recently reviewed the Warm Springs Water Treatment Plant's (WSWTP) bacteriological results for total coliform and E. coli, along with chlorine residual levels sampled on August 12 and 13, 2019. Based on information provided by the Warm Springs Tribe today after the line/ PRV repair was completed, sampling results indicate that both total coliform

and E. coli were absent and free chlorine residual levels have returned to baseline levels. As a result, the EPA Region 10 concurs with Warm Springs assessment that the BWN for WSWTP can be lifted.

Thanks.



Adam Baron

Drinking Water Enforcement Officer
Field, Data, & Drinking Water Enforcement Section
Enforcement and Compliance Assurance Division
U.S. Environmental Protection Agency, Region 10
1200 Sixth Avenue, Suite 155
Seattle, Washington 98101
Office (206) 553-6361
baron.adam@epa.gov
